

第1配水場配水区域 羽村市川崎693-1武蔵野小学校（残留塩素濃度）

（単位：mg/L）

日	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
1	0.28											
2	0.28											
3	0.28											
4	0.27											
5	0.27											
6	0.26											
7	0.26											
8	0.25											
9	0.24											
10	0.23											
11	0.22											
12	0.22											
13	0.23											
14	0.22											
15	0.21											
16	0.19											
17	0.17											
18	0.23											
19	0.27											
20	0.27											
21	0.27											
22	0.27											
23	0.27											
24	0.28											
25	0.28											
26	0.28											
27	0.28											
28	0.27											
29	0.28											
30	0.28											
31												
最高	0.28											
最低	0.17											
平均	0.25											

※ 国の基準値：0.1mg/L以上

※ 水質管理上の目標値：0.1mg/L以上1.0mg/L以下

羽村市上下水道部