

第2配水場低区配水区域 羽村市羽中4-10-3 羽村市浄水場(残留塩素濃度)

(単位:mg/L)

日	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
1	0.29	0.30	0.29									
2	0.29	0.29	0.29									
3	0.30	0.28	0.29									
4	0.30	0.29	0.28									
5	0.30	0.29	0.27									
6	0.29	0.28	0.27									
7	0.29	0.28	0.26									
8	0.28	0.27	0.26									
9	0.27	0.27	0.27									
10	0.25	0.27	0.27									
11	0.24	0.28	0.30									
12	0.24	0.28	0.32									
13	0.24	0.27	0.32									
14	0.24	0.27	0.31									
15	0.23	0.27	0.29									
16	0.22	0.27	0.28									
17	0.19	0.27	0.28									
18	0.18	0.27	0.28									
19	0.26	0.28	0.27									
20	0.29	0.29	0.27									
21	0.29	0.28	0.27									
22	0.29	0.27	0.27									
23	0.29	0.28	0.27									
24	0.29	0.29	0.26									
25	0.29	0.29	0.26									
26	0.30	0.28	0.26									
27	0.30	0.28	0.26									
28	0.30	0.28	0.26									
29	0.30	0.28	0.27									
30	0.30	0.28	0.26									
31		0.28										
最高	0.30	0.30	0.32									
最低	0.18	0.27	0.26									
平均	0.27	0.28	0.28									

※ 国の基準値:0.1mg/L以上

※ 水質管理上の目標値:0.1mg/L以上1.0mg/L以下

羽村市上下水道部