

第2配水場高区配水区域 羽村市緑ヶ丘2-18-5 水道事務所（残留塩素濃度）

（単位：mg/L）

日	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
1	0.23											
2	0.23											
3	0.24											
4	0.23											
5	0.23											
6	0.22											
7	0.21											
8	0.22											
9	0.21											
10	0.19											
11	0.19											
12	0.19											
13	0.19											
14	0.18											
15	0.17											
16	0.17											
17	0.14											
18	0.16											
19	0.22											
20	0.23											
21	0.19											
22	0.22											
23	0.22											
24	0.23											
25	0.23											
26	0.23											
27	0.22											
28	0.22											
29	0.23											
30	0.23											
31												
最高	0.24											
最低	0.14											
平均	0.21											

※ 国の基準値：0.1mg/L以上

※ 水質管理上の目標値：0.1mg/L以上1.0mg/L以下

羽村市上下水道部