

第2配水場低区配水区域 羽村市羽中4-10-3 羽村市浄水場(残留塩素濃度)

(単位:mg/L)

日	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
1	0.29											
2	0.29											
3	0.30											
4	0.30											
5	0.30											
6	0.29											
7	0.29											
8	0.28											
9	0.27											
10	0.25											
11	0.24											
12	0.24											
13	0.24											
14	0.24											
15	0.23											
16	0.22											
17	0.19											
18	0.18											
19	0.26											
20	0.29											
21	0.29											
22	0.29											
23	0.29											
24	0.29											
25	0.29											
26	0.30											
27	0.30											
28	0.30											
29	0.30											
30	0.30											
31												
最高	0.30											
最低	0.18											
平均	0.27											

※ 国の基準値:0.1mg/L以上

※ 水質管理上の目標値:0.1mg/L以上1.0mg/L以下

羽村市上下水道部