

第1配水場配水区域 羽村市川崎693-1武蔵野小学校 (残留塩素濃度)

(単位: mg/L)

日	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
1	0.30											
2	0.31											
3	0.31											
4	0.30											
5	0.30											
6	0.29											
7	0.30											
8	0.30											
9	0.29											
10	0.30											
11	0.32											
12	0.36											
13	0.31											
14	0.29											
15	0.28											
16	0.28											
17	0.30											
18	0.29											
19	0.27											
20	0.25											
21	0.23											
22	0.23											
23	0.22											
24	0.27											
25	0.28											
26	0.28											
27	0.28											
28	0.28											
29	0.29											
30	0.29											
31												
最高	0.36											
最低	0.22											
平均	0.29											

※ 国の基準値: 0.1mg/L以上

※ 水質管理上の目標値: 0.1mg/L以上 1.0mg/L以下

羽村市上下水道部