

第2配水場高区配水区域 羽村市緑ヶ丘2-18-5 水道事務所 (残留塩素濃度)

(単位: mg/L)

日	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
1	0.26											
2	0.27											
3	0.28											
4	0.27											
5	0.26											
6	0.26											
7	0.27											
8	0.27											
9	0.27											
10	0.27											
11	0.26											
12	0.34											
13	0.32											
14	0.27											
15	0.25											
16	0.25											
17	0.25											
18	0.27											
19	0.26											
20	0.23											
21	0.21											
22	0.21											
23	0.20											
24	0.21											
25	0.25											
26	0.25											
27	0.25											
28	0.25											
29	0.22											
30	0.24											
31												
最高	0.34											
最低	0.20											
平均	0.26											

※ 国の基準値: 0.1mg/L以上

※ 水質管理上の目標値: 0.1mg/L以上 1.0mg/L以下

羽村市上下水道部