

第2配水場低区配水区域 羽村市羽中4-10-3 羽村市浄水場（残留塩素濃度）

（単位：mg/L）

日	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
1	0.27											
2	0.27											
3	0.28											
4	0.27											
5	0.28											
6	0.27											
7	0.27											
8	0.27											
9	0.26											
10	0.25											
11	0.26											
12	0.32											
13	0.33											
14	0.27											
15	0.26											
16	0.25											
17	0.25											
18	0.26											
19	0.26											
20	0.24											
21	0.21											
22	0.20											
23	0.21											
24	0.20											
25	0.24											
26	0.25											
27	0.26											
28	0.26											
29	0.26											
30	0.26											
31												
最高	0.33											
最低	0.20											
平均	0.26											

※ 国の基準値：0.1mg/L以上

※ 水質管理上の目標値：0.1mg/L以上 1.0mg/L以下

羽村市上下水道部