

第Ⅰ配水場配水区域 羽村市川崎693-1武蔵野小学校（残留塩素濃度）

（単位：mg/L）

| 日  | 4月   | 5月   | 6月 | 7月 | 8月 | 9月 | 10月 | 11月 | 12月 | 1月 | 2月 | 3月 |
|----|------|------|----|----|----|----|-----|-----|-----|----|----|----|
| 1  | 0.30 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 2  | 0.31 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 3  | 0.31 | 0.28 |    |    |    |    |     |     |     |    |    |    |
| 4  | 0.30 | 0.28 |    |    |    |    |     |     |     |    |    |    |
| 5  | 0.30 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 6  | 0.29 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 7  | 0.30 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 8  | 0.30 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 9  | 0.29 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 10 | 0.30 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 11 | 0.32 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 12 | 0.36 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 13 | 0.31 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 14 | 0.29 | 0.28 |    |    |    |    |     |     |     |    |    |    |
| 15 | 0.28 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 16 | 0.28 | 0.28 |    |    |    |    |     |     |     |    |    |    |
| 17 | 0.30 | 0.28 |    |    |    |    |     |     |     |    |    |    |
| 18 | 0.29 | 0.28 |    |    |    |    |     |     |     |    |    |    |
| 19 | 0.27 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 20 | 0.25 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 21 | 0.23 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 22 | 0.23 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 23 | 0.22 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 24 | 0.27 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 25 | 0.28 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 26 | 0.28 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 27 | 0.28 | 0.28 |    |    |    |    |     |     |     |    |    |    |
| 28 | 0.28 | 0.28 |    |    |    |    |     |     |     |    |    |    |
| 29 | 0.29 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 30 | 0.29 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 31 |      | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 最高 | 0.36 | 0.29 |    |    |    |    |     |     |     |    |    |    |
| 最低 | 0.22 | 0.28 |    |    |    |    |     |     |     |    |    |    |
| 平均 | 0.29 | 0.29 |    |    |    |    |     |     |     |    |    |    |

※ 国の基準値：0.1mg/L以上

※ 水質管理上の目標値：0.1mg/L以上 1.0mg/L以下

羽村市上下水道部