

第2配水場低区配水区域 羽村市羽中4-10-3 羽村市浄水場（残留塩素濃度）

（単位：mg/L）

日	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
1	0.27	0.26										
2	0.27	0.26										
3	0.28	0.26										
4	0.27	0.25										
5	0.28	0.26										
6	0.27	0.26										
7	0.27	0.26										
8	0.27	0.26										
9	0.26	0.26										
10	0.25	0.26										
11	0.26	0.26										
12	0.32	0.26										
13	0.33	0.25										
14	0.27	0.25										
15	0.26	0.25										
16	0.25	0.25										
17	0.25	0.25										
18	0.26	0.25										
19	0.26	0.25										
20	0.24	0.25										
21	0.21	0.25										
22	0.20	0.25										
23	0.21	0.25										
24	0.20	0.26										
25	0.24	0.27										
26	0.25	0.26										
27	0.26	0.25										
28	0.26	0.26										
29	0.26	0.25										
30	0.26	0.26										
31		0.26										
最高	0.33	0.27										
最低	0.20	0.25										
平均	0.26	0.26										

※ 国の基準値：0.1mg/L以上

※ 水質管理上の目標値：0.1mg/L以上 1.0mg/L以下

羽村市上下水道部